



ANNUAL AND FIVE YEAR TEST REPORTING FORM FIRE SERVICE / EMERGENCY POWER

ELEVATOR SAFETY INSPECTION 1100 N. EUTAW STREET, ROOM 601 BALTIMORE, MD 21201

The Department is authorizing qualified personnel to perform specific tests during the annual and five year inspection periods. ALL WORK IS TO BE PERFORMED IN ACCORDANCE WITH THE REQUIREMENTS OF THE APPROPRIATE ASME A17.1 CODE.

For each elevator tested, list the State Registration number found in the elevator machine room:

A. SMOKE SENSING DEVICES - Applicable Code Year: _____

All smoke sensors related to the elevator operation except designated level, returned elevator(s) to the designated level (key floor)

[] Yes [] No The designated floor sensor sent the elevator(s) to the alternate level, floor number _____ as required by the ASME A17.1 Elevator Code.

B. STAND-BY EMERGENCY POWER TEST - Applicable Code Year: _____

CHECK ONE: [] ANNUAL TEST ASME A17.1 [] FIVE YEAR TEST ASME A17.1

[] OTHER:

Annually, elevator(s) equipped with stand-by emergency power are required to be tested using the emergency power system with no load.

1. Did the elevator(s) operate simultaneously while on stand-by emergency power? [] Yes [] No

If NO, explain:

2. Did the elevators operate in accordance with the above elevator Code? [] Yes [] No

Form with fields for Site Name, Address, City, State, Zip, Testing Firm, Date Tested, Printed Name of Authorized Agent, and Authorized Agent's Signature.

WHEN COMPLETED, LEAVE FORM IN THE ELEVATOR MACHINE ROOM.